



cfo@vmc.gov.in



FORM B 13.3  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOVMC/2021/00010876  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOVMC/2021/00010876/R1

Date: 03/09/2024

Building Occupancy/Category: Educational (non-residential)

To,

pavan jivani  
OPP BARODA CENTRAL CO OP BANK BAJWA REFINERY ROAD AT BAJWA VADODARA Vadodara MC 391310  
Fire Region: Vadodara MC  
Mobile No: 8141393453 Email ID: pavanjivani123@gmail.com

This has reference to your Application No. 2024/00080003 dated 12/08/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise **VIBRANT WAVES INTERNATIONAL ACADEMY** (name of the Building/ Project), as per below mentioned details:


1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: VADODARA
5. Name of Block(s): VIBRANT WAVES INTERNATIONAL ACADEMY


The building/premise was inspected on **03/09/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **03/09/2024**
2. Six monthly inspection was done on **03/09/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **03/09/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

  
MANAGER  
VIBRANT WAVES INTERNATIONAL ACADEMY  
BAJWA, VADODARA

  
PR



AFFILIATION NO. 430386  
SCHOOL CODE 10362

Digitally Verified

Digitally Verified by: Kantibhai Ashikbhai Patel  
Fire Safety Officer - Advance (FSO-A)  
2021/000232

Date: 03/09/2024  
Time: 03:01 PM



FSCA/O/CFOVMC/2021/00010876/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.